

## 3/71

PA24 BREWSTER

Division of Environmental Health Services

COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

P1106

41 28 41 73 36 54

OWNER	NAME <b>FORRESTER BUILDERS</b>		ADDRESS <b>PATTERSON NY</b>	
LOCATION OF WELL	(No. & Street) <b>MOUNTAIN VIEW RD</b>		(Town) <b>PATTERSON NY</b>	(Lot Number)
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC <input type="checkbox"/> BUSINESS ESTABLISHMENT <input type="checkbox"/> FARM <input type="checkbox"/> TEST WELL <input type="checkbox"/> PUBLIC SUPPLY <input type="checkbox"/> INDUSTRIAL <input type="checkbox"/> AIR CONDITIONING <input type="checkbox"/> OTHER (Specify) <b>630 5</b>			
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY <input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION <input type="checkbox"/> CABLE PERCUSSION <input type="checkbox"/> OTHER (Specify)			
CASING DETAILS	LENGTH (feet) <b>20</b>	DIAMETER (inches) <b>7" OD</b>	WEIGHT PER FOOT <b>23</b>	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED DRIVE SHOE: <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO    WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED <input type="checkbox"/> PUMPED <input checked="" type="checkbox"/> COMPRESSED AIR		HOURS <b>1 Hr</b>	G.P.M. <b>6</b> YIELD (G.P.M.) <b>6</b>
WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet) <b>15'</b>		DURING YIELD TEST (feet) <b>Total DRAW DOWN</b> Depth of Completed Well in feet below land surface: <b>165'</b>	
SCREEN DETAILS	MAKE			LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches): GRAVEL SIZE (inches) FROM (feet) TO (feet)
DEPTH FROM LAND SURFACE	FORMATION DESCRIPTION		Sketch exact location of well with distances, to at least two permanent landmarks.	
FEET to FEET				
<b>0</b>	<b>3'</b>	<b>OVER burden</b>		
<b>3'</b>	<b>165'</b>	<b>ledge</b>		
If yield was tested at different depths during drilling, list below				
FEET	GALLONS PER MINUTE			
DATE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature)	BOYD AMESIAN WELL CO. RFD 3 ROCHESTER CHAMPLAIN, N.Y.	
<b>9/25/71</b>	<b>10/13/71</b>	<b>Forrester Builders</b>		